



LERBAKKEN 10, 8410 RØNDE DENMARK

## ATEX/JKE Installation drawing

For safe installation of 9203 the following must be observed. The module shall only be installed by qualified personnel who are familiar with the national and international laws, directives and standards. Year of manufacture of the module shall be indicated by the first two digits in the serial number.

For installation in Zone 2 / Division 2 the following must be observed:  
The 4501 programming module is to be used solely with PR electronics modules. It is important that the module is undamaged and has not been altered or modified in any way. Only 4501 modules free of damage shall be installed.

ATEX Certificate: KEMA 07ATEX 0147 X  
JKE Certificate: 9203EXXX-X Pending  
DEKRA 21UKEXXXXXX-X  
Marking: 9203Bxxx, 9203Axxx

Marking: 9203Bxxx, 9203Axxx  
II 3G Ex ec IIC T4 Gc  
Standards: EN 60079-0 : 2018, EN 60079-11 : 2012, EN 60079-15 : 2017, EN 60079-20 : 2019+A1:2018

Special Conditions of Use:  
Initial torque 0.5 Nm.  
Do not separate connectors when energized and an explosive gas mixture is present.  
Do not mount or remove modules from the Power Rail when an explosive gas mixture is present.  
Disconnect power before service.

The wiring can be up to 10 mm².  
In type of protection (Ex ia) Da it is Da! The parameters for intrinsic safety for gas group IIb are applicable.

For installation in Zone 2, the module shall be installed in an enclosure in type of protection Ex e, providing a degree of protection of at least IP54. Cable entry devices and blanking elements shall fulfil the same requirements.

For installation on Power Rail in Zone 2, only Power Rail type 9400 supplied by Power Control Unit type 9410 (ATEX/JKE) or Power Rail type 9400 supplied by Power Control Unit type 9410 (ATEX/JKE) conformity. DEKRA KEM 00023X is allowed.

Max. screw terminal torque 0.5 Nm.

Stranded wire should be installed with an insulation stripping length of 6 mm or via a suitable insulated terminal such as a bootstrap ferrule.

Revision date: 2022-08-19 Version Revision: V8R0 Prepared by: MMA Page: 1/4

Revision date: 2022-08-19 Version Revision: V8R0 Prepared by: MMA Page: 2/4

Revision date: 2022-08-19 Version Revision: V8R0 Prepared by: MMA Page: 3/4

Revision date: 2022-08-19 Version Revision: V8R0 Prepared by: MMA Page: 4/4

LERBAKKEN 10, 8410 RØNDE DENMARK

## IECEx Installation drawing

For safe installation of 9203 the following must be observed. The module shall only be installed by qualified personnel who are familiar with the national and international laws, directives and standards. Year of manufacture of the module shall be indicated by the first two digits in the serial number.

For installation in Zone 2 / Division 2 the following must be observed:  
The 4501 programming module is to be used solely with PR electronics modules. It is important that the module is undamaged and has not been altered or modified in any way. Only 4501 modules free of damage shall be installed.

IECEx Certificate: IECEx KEM 00.0001X

Marking: 9203Bxxx, 9203Axxx

(Ex ia Ga) IIC/IB/II  
(Ex ia Mb)  
(Ex ia M1)

Marking: 9203Bxxx, 9203Axxx

Ex m IIIC T4 Gc

Standards: IEC60079-0:2017, IEC60079-11:2011, IEC60079-15:2017, IEC60079-7:2015+A1:2017

Type Installation Non Ex Zone 2 JA Low current -1 A Input Channels A Standard :-1

Ex-Banner / Zone 2 IB High current -2 Single -A NPN :-1

Installation notes:  
Initial torque 0.5 Nm.

Do not separate connectors when energized and an explosive gas mixture is present.

Disconnect power before service.

The wiring can be up to 10 mm².

In type of protection (Ex ia) Da it is Da! The parameters for intrinsic safety for gas group IIb are applicable.

For installation in Zone 2, the module shall be installed in an enclosure in type of protection Ex e, providing a degree of protection of at least IP54. Cable entry devices and blanking elements shall fulfil the same requirements.

For installation on Power Rail in Zone 2 only Power Rail type 9400 supplied by Power Control Unit type 9410 (ATEX/JKE) or Power Rail type 9400 supplied by Power Control Unit type 9410 (ATEX/JKE) conformity. DEKRA KEM 00023X is allowed.

Max. screw terminal torque 0.5 Nm.

Stranded wire should be installed with an insulation stripping length of 6 mm or via a suitable insulated terminal such as a bootstrap ferrule.

Revision date: 2022-02-14 Version Revision: V7R0 Prepared by: MMA Page: 1/4

Revision date: 2022-02-14 Version Revision: V7R0 Prepared by: MMA Page: 2/4

Revision date: 2022-02-14 Version Revision: V7R0 Prepared by: MMA Page: 3/4

Revision date: 2022-02-14 Version Revision: V7R0 Prepared by: MMA Page: 4/4

LERBAKKEN 10, 8410 RØNDE DENMARK

## IECEx 설치도면

9203Bxxx의 IECEx 설치도면은 사용자에게 정기적인 안전 및 보호 기능을 제공하는 최적화된 설치 방법을 제공합니다. 이 설치도면은 9203Bxxx 모듈이 IECEx 인증을 받았음을 증명하는 IECEx KEM 00.0001X를 포함합니다.

모듈은 9203Bxxx 모듈은 IECEx KEM 00.0001X를 포함합니다.

IECEx KEM 00.0001X

IECEx KEM 00.0001X